

Analysis on The Risk of Respiratory Virus Transmission By Air Conditioning System Operation-Based on Experimental Evidence

Yonghong Jia

Sichuan University

Yue Xiang

Sichuan University

Shurui Guo

Sichuan University

Lei Guo

Sichuan University

Luyao Guo

Sichuan University

Zhu Cheng

Sichuan University

Yin Zhang

Sichuan University - Wangjiang Campus: Sichuan University

Li Zhang

Sichuan University

Enshen Long (✉ longes2@163.com)

Sichuan University <https://orcid.org/0000-0003-0774-4275>

Research Article

Keywords: central air-conditioned room, environmental regulation, circulating air, respiratory viruses, virus survival test, transmission risk

Posted Date: February 15th, 2021

DOI: <https://doi.org/10.21203/rs.3.rs-192895/v1>

License:   This work is licensed under a Creative Commons Attribution 4.0 International License.

[Read Full License](#)

Abstract

It is important to know whether SARS-CoV-2 is spread through the air-conditioning systems. Taking the central air-conditioning system as an example, we analyze the mechanism and potential health risk of respiratory virus transmission in air-conditioned rooms, and propose a method to study the risk of virus transmission in central air-conditioning systems by investigating the data from medical experiments. The virus carrying capacity and the decay characteristics of indoor pathogen droplets are studied in this research. Additionally, the effects of air temperature and relative humidity on the virus survival in the air or on surfaces are investigated. The removal efficiency of infectious droplet nuclei by air-conditioning filter was then determined. Thus, the transmission risk during the operation of centralized air-conditioning system is evaluated. The results show that the indoor temperature and humidity are controlled in the range of 20-25°C and 40%-70% by central air-conditioning during the epidemic period, which not only benefits the health and comfort of residents, but also weakens the vitality of the virus. The larger the droplet size, the longer the viruses survive. Since the filter efficiency of air-conditioning filter increases with the increase of particle size, increasing the number of air changes of the circulating air volume can accelerate the removal of potential pathogen particles. Therefore, scientific operation of centralized air conditioning systems during the epidemic period has more advantages than disadvantages.

1. Introduction

Since the end of 2019, the COVID-19 epidemic caused by SARS-COV-2 coronavirus has spread rapidly around the world, reaching more than 200 countries and regions with global implication("WHO announces COVID-19 outbreak a pandemic (<http://www.euro.who.int/en/health-topics/health-emergencies/coronavirus-covid-19/news/news/2020/3/who-announces-covid-19-outbreak-a-pandemic>),"). At present, epidemic prevention and control has become a major issue in China and even all over the world. In particular, whether SARS-CoV-2 spreads through the air conditioning system has drawn wide attention(Correia et al., 2020).

First, we need to understand how SARS-CoV-2 is transmitted. At present, it has been determined that the main transmission routes are through droplets and physical contact(Hoseinzadeh et al., 2020). It is not clear whether aerosols constitute one of the transmission routes, and has also been the focus of debate among scholars. Recently, a team of 239 interdisciplinary scientists signed a document urging the WHO and public health authorities to recognize the airborne transmission of SARS-CoV-2(Morawska et al., 2020). Studies have shown that most people spend 90% of their lives indoors(Klepeis et al., 2020; Wang et al., 2015). In a crowded confined space, the droplets exhaled by SARS-CoV-2 infected patients through breathing, speaking, coughing and other activities will form virus-containing aerosols(Morawska et al., 2006; Li et al., 2020), and the virus may spread through these aerosols, a risk that should not be underestimated. For example, on February 3, 2020, a case of COVID-19 was reported in Inner Mongolia, China. The patient had repeatedly entered the room of a symptomatic patient but did not have directly contacted with the patient. This case suggests that SARS-CoV-2 may spread through the air(Wang et al.,

2020). By analyzing trends of epidemic spread in Wuhan, China, Italy and New York, the results of a recent study suggest that air contributes to the spread of SARS-CoV-2(Zhang et al., 2020).

Regarding the risk of indoor virus transmission, in 2010, Chen and Liao(Chen & Liao, 2010) studied the transmission risk of different influenza viruses in an indoor environment based on the Wells Riley mathematical model, and the results showed that the risk of indoor virus infection was negatively correlated with the air changes per hour (ACH) rate, where ACH is the ratio of the amount of clean air entering a room (m³/h) to the room (m³) per hour. In 2013, Cheng and Liao(Cheng & Liao, 2013) used a multi-control measure model for influenza to study the risk control effect of H1N1 in indoor transmission, and revealed that the uncontrollable rate of influenza decreased with increase of the ACH rate. In 2020, in response to the outbreak of COVID-19, some scholars assessed the transmission risk of SARS-CoV-2 in the air. The team of Buonanno(Buonanno et al., 2020) emphasized the importance of ventilation in indoor environments in reducing the risk of infection.

Can the Coronaviruses spread through the air-conditioning systems? There are three major opinions on this issue. 1) There is evidence showing that the viruses can spread through air conditioning systems. Since the Philadelphia Legionnaires Incident in 1976(Farnham et al., 2014), scholars have repeatedly argued that the operation of air-conditioning is beneficial to the spread of germs. They believe that the droplets produced by pathogen carriers through coughing, sneezing and other activities cannot be effectively contained even by powerful air-conditioning airflows. On the contrary, inappropriate airflows of the air conditioner will help the spread of droplets(["https://www.buildup.eu/en/practices/publications/covid-19-guidance-rehva,"](https://www.buildup.eu/en/practices/publications/covid-19-guidance-rehva) ; Perera et al., 2020; Lu et al., 2020; Pan et al. , 2020; Siddiqui et al., 2020). From January to February 2020, an outbreak of COVID-19 occurred in an air-conditioned restaurant in Guangzhou, China. Lu et al.(Lu et al., 2020) concluded that air-conditioned ventilation promoted the spread of SARS-CoV-2 in the restaurant after examining the potential transmission routes of the case. Correia et al.(Correia et al., 2020) also pointed out that improper use of air-conditioning systems may lead to SARS-COV-2 transmission after reviewing the possible impact of HVAC on building virus transmission. 2) There is no evidence showing that the viruses can spread through air conditioning systems. The argument is that there is currently no evidence that the viruses can spread through air conditioning systems. COVID-19 is a global pandemic, with more than 27 million confirmed cases("WHO, WHO Coronavirus Disease (COVID-19) Dashboard, 2020. <https://covid19.who.int/>,"). Statistically speaking, the sample size is large enough, and many confirmed COVID-19 cases can be traced back to the origin. However, none of the medical records so far has clearly indicated that the cause is due to the centralized air conditioning system, so it is impossible to determine whether the air conditioning system spreads the viruses("<https://health.clevelandclinic.org/does-air-conditioning-spread-the-coronavirus/>,").3) There is evidence that air-conditioning systems work against the spread of viruses. This opinion is represented by the American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE) ("<https://www.ashrae.org/technical-resources/resources>," ; "<https://www.cibse.org/coronavirus-covid-19/coronavirus-covid-19-and-hvac-systems>,").In a statement ("<https://www.ashrae.org/technical-resources/resources>," ; "<https://www.cibse.org/coronavirus-covid-19/coronavirus-covid-19-and-hvac-systems>,") on the relationship between COVID-19 and HVAC in

buildings, it is clearly stated that ASHRAE opposes the recommendation not to use the HVAC system during the epidemic, and maintains that keeping the air conditioning on during this period can help control the spread of the viruses. The press release issued by the German Association of Raumluftechnische Geraete herstellerverband e.V.(RLT) on March 26, 2020("https://rlt-geraete.de/") also expressed support for the viewpoint of epidemic prevention by air-conditioning operation. However, due to the lack of academic supporting evidence, it is clearly argued that this is a minority view.

The situation in Chinese COVID-19 epidemic prevention and control continues to improve. Under the conditions of normalization of prevention and control, it is required to accelerate the restoration of production and life order, and actively promote the resumption of work and production in an orderly manner. Commercial industries such as restaurants have opened their doors one after another. The northern hemisphere has entered early winter after the hot summer, and the southern hemisphere has entered an early summer. Therefore, will the operation of the centralized air conditioning system with return air increase the risk of virus transmission during the epidemic? This is a matter of public concern, government worry, and academic controversy, which is well worth studying. However, the three views are now the mainstream controversy and the deadlock of opposition cannot be broken. The key reason is that the opinions are either based on the observation of epidemiological phenomena or the empirical inference of their respective disciplines, without the support of relevant medical virus experiments. In this paper, we take the air conditioning system with single return air as an example and systematically study the risk of SARS-CoV-2 spreading in a centralized air-conditioning operation room from a unique perspective based on medical experiments, thus filling in the gap.

2. Analysis And Methodology Of Transmission Mechanism

Medical evidence-based experiment is a method to first analyze the mechanism of the influence of respiratory virus on indoor person-to-person transmission, then to use the medical experimental evidence of the indoor environment for virus survival and infection among animals, further-more to study the risk of virus transmission of the main measures for the operation and control of centralized air-conditioning systems, and finally the optimal operation strategy of centralized air-conditioning for prevention and control during the outbreak to be put forward. The medical experiments include: particle size distribution of exhaled droplets, evaporation concentration process and viral load of infected persons, the influence of temperature and humidity on virus decay and animal infection, and the effect of filter on the removal of potential pathogen particles, etc.

The COVID-19 is a respiratory infectious disease. Its transmission in population includes three processes: occurrence, spread, and termination. The transmission process must have three basic links: the source of infection, the route of transmission, and the susceptible people(Lindsley et al., 2012; Zhao et al., 2010). Individual breathing activities and interpersonal social behavior are the main sources of transmission, and the factors affecting the transmission risk are very complex. In order to focus on the research topic, we only analyze the transmission mechanism of respiratory viruses in the indoor space of the primary return air centralized air conditioning system, as shown in Figure 1. Through breathing, talking, coughing,

sneezing and other behavior, the droplets or deposits on the surface of objects are released by the infected person into the ambient air. If the droplets or deposits are inhaled or touched by susceptible people again through close contact or close social activities, the infection spread might occur. When the viruses are inside of the host's body, the temperature is appropriate, the water is sufficient, the protein nutrition composition is rich, the salt is moderate, the acid is balanced, and the environment is optimal. Once the droplets leave the host and enter the indoor environment, they must undergo the physical process of increasing the water evaporation and component concentration. The temperature, relative humidity, air speed and surface characteristics of the environmental space have a direct impact on the droplets and droplet nuclei carrying pathogens in regard to particle size, distribution and movement characteristics. Therefore, the new environment is also an important factor influencing the survival and spread of the viruses. The centralized air-conditioning system that regulates indoor temperature and humidity, air quality, and airflow organization makes the mechanism of indoor virus transmission more complicated.

The main four functions of the conventional centralized air conditioning system are as follows: The first is to adjust the indoor temperature and relative humidity to an appropriate range for human comfort. The second is to reduce the concentration of pollutants through fresh air to ensure indoor hygiene requirements. The third is to partially remove indoor particulate pollutants through the primary and medium-efficiency filters installed in the air treatment box, thereby improving indoor air quality. For heavily polluted areas or special buildings such as hospitals, high-efficiency air purifiers are also installed in the systems to further improve indoor air quality. The fourth is to enhance the system's heat and humidity load regulation capacity through partial return air and reduce the energy consumption of the air conditioning system. However, during the outbreak of the epidemic, some regulation functions of the conventional centralized air-conditioning systems were questioned, which might increase the risk of epidemic transmission. For example, the return air flow processed by the air-conditioning systems is returned to each room, which may cause the spread of potential pathogens. Then, after the filters and purifiers in the system capture the particles of potential pathogens, they may enter each room through the air supply again, and the pathogens collected on the filter layer may breed multiply. In addition, due to the various forms of airflow organization in the centralized air-conditioning systems, small droplets and droplet nuclei can easily float in the air. The contact methods of infected and susceptible individuals in centralized air-conditioned rooms are uncertain. All of the above give people reason to doubt that air-conditioning operation will increase the risk of transmission.

Due to the concerns about these potential risks, some professional institutions may suggest the following strategies when formulating guidelines for the operation and prevention of centralized air-conditioning systems in public buildings during the epidemic (Pan et al., 2020; "REHVA_COVID-19_guidance_document_ver2_20200403_"). Firstly, turn on as little as possible or completely stop the use of centralized air-conditioning systems. However, the downside is huge, because the amount of public buildings with air-conditioning systems is massive, and the air-conditioning system operation is the basic guarantee for restoring the social order of business. Stopping the operation of the air conditioning system may cause the indoor temperature and humidity too high or too low, and the indoor air quality will

decrease, thus affecting the health of indoor personnel. Secondly, it is recommended to close the return air, and operating all fresh air instead. However, since the design air volume of the fresh air system can only take a small part of the total load of the building, it is far from achieving indoor thermal comfort. The third is to transform and increase the fresh air systems, but this is a complex system project. For existing public buildings, the expansion of the pipeline system and equipment room is subject to large space constraints, and the practical conditions are limited. In particular, the increase of the fresh air volume has a significant impact on the air-conditioning heating load, but the original matching host is difficult to bear, resulting in most of it impossible to implement. Fourth, it suggests to try to open doors and windows for ventilation when the air-conditioning heating system is running. However, since the amount of natural ventilation entering the room through doors and windows is greatly affected by the outdoor wind speed and is hard to control, the magnitude of fresh air changes (ACH) may be as high as 30~50/h (Haquin et al., 2013) even when the doors and windows are 10% open. This approach may cause the air-conditioning load sharply increasing. At this time, even if the system matched with the original design is running at full capacity, it is only a drop in the bucket. Therefore, this proposal not only wastes energy, but also sacrifices the comfort of indoor personnel.

The experts in the field of built environment concerned that the operation of centralized air-conditioning systems may increase the risk of transmission is not groundless, and the prevention and control technology recommendations are also based on the common sense of environmental disciplines and are well-founded. However, the transmission of the epidemic is a very complex interdisciplinary issue. It not only needs to conform to the common sense of indoor environmental control disciplines, but also needs to respect the basic laws of virus survival and spread. Only when these two are combined and the main contradiction of indoor transmission risk is recognized, can the prevention and control technology strategies be more accurate. Evidence-based medical experiment is not only the blind spot of the current research, but is also the key to realize the breakthrough of knowledge.

Based on the above analysis, we propose a specific method of evidence-based medical experiments. First of all, droplets (droplet nuclei) are not only the pollution sources that diffuses in indoor environment with the air supply and return air of centralized air-conditioning systems, but also are the potential pathogen particles captured by the air filters and purifiers, the source of respiratory diseases such as the SARS-COV-2 virus. Through the medical experiments, we can understand the viral load of the mouth, nose and throat fluids of infected persons, the number and distribution of particle sizes of droplets released by various respiratory activities (breathing, speaking, coughing and sneezing) of infected persons, and the difference of the potential virus carrying amount of different particle sizes. These form the basis for discriminating and analyzing the floating, settling and moving trajectory of indoor pathogen particles, and then allow studying the transmission risks of air conditioning system return air and filter operation.

Secondly, with the goal of keeping human health and comfort, the regulation of indoor temperature and relative humidity is the most important part of the operation of air-conditioning systems. However, which kind of temperature and relative humidity is the most unfavorable for the survival of respiratory viruses and the most unfavorable for the spread of viruses are the questions that must be answered through

evidence-based medical experiments. Only by combining the advantages of human health and comfort with the disadvantages of virus survival and transmission can a more scientific and precise control strategy can be proposed for the operation air-conditioning systems during the outbreak. The indoor temperature and humidity largely determine the physical fate of droplets exhaled from an infected person. Because under a certain temperature and humidity conditions, the water evaporation rate and the increase rate of the concentration of each component of the viral-containing liquid drops with different volume or diameter in the air or on the surface of the object are different, which directly affects the speed of the decay process. While opening doors and windows or increasing the fresh air volume during the operation of the air conditioning system can reduce the concentration of indoor pathogens, it will significantly increase the air conditioning heating and cooling load and energy consumption. The coupling changes of indoor temperature and humidity will lead to changes in the law of virus survival and transmission, which is an important proposition that requires medical evidence to answer.

Thirdly, the filter is also an important device in the air-conditioning systems to remove particulate pollutants and improve air quality. During the epidemic, the one-time removal efficiency of potential pathogen particles and the potential risk of transmission also must be evidence-based through medical experiments. The moisture of the droplets exhaled by an infected person evaporates quickly and becomes a droplet nucleus, which may float in the air for a long time and flow with the air-conditioning systems, causing spread risk. More than 98% of the droplets are water, and the rest are protein nutrients and trace components. The ratio of the droplet core particle size to the initial particle size after evaporation is about 0.25~0.35(Mao et al., 2020). Because the size of droplets varies widely, and the volume of droplets of different particle sizes is proportional to the cube of the particle size, for example, the volume of a 10 μ m particle is equivalent to more than 1000 times that of 1 μ m, so the spread risk varies greatly. Therefore, for the transmission risk assessment of filters or air purifiers in air-conditioning systems during the epidemic, attention should not only be paid to the filtration efficiency at the rated working condition (0.3), but also to the removal efficiency of particulate matter with a large particle size range, and the global analysis of the survival behavior of the viruses on the object surfaces (filter layers) should also be considered. These all need the support of medical experiment evidence.

Finally, based on the above methodology, the transmission risk of the operation of primary return air centralized air-conditioning systems is discussed in depth.

Annotation T Temperature RH Relative Humidity

3. Results

3.1 Transmission risk of indoor pathogens

(1) The differences in virus concentration of different particle sizes

In the indoor environment, the source of the risk of virus transmission is that when there are virus carriers in the room, toxic droplets exhaled through coughing, sneezing and other behaviors may be inhaled by

susceptible people, thus causing the spread of the viruses(Olsen et al., 2003; Qu et al., 2020). We need to understand the viral load of the mouth, nose, and throat swabs of infected persons (or asymptomatic patients) through the medical measurements, as well as measuring the particle size range and volume distribution of droplets released by respiratory activities into the room. It is the basis for the air-conditioning and ventilation system to transmit the virus-containing droplets and nuclear particles, and investigating the risk of virus disease transmission.

In medicine, the real-time RT-PCR virus nucleic acid test of the swab of the mouth, nose and throat of the population or patient is generally used to judge the infection and its severity(Guarnieri & Balmes, 2014). Since the outbreak of the COVID-19 epidemic, there have been many reports on the viral load data of patients. Zou et al. (Zou et al., 2020) and Cao et al.(Cao et al., 2020) tested 6 patients and 199 SARS-CoV-2 patients who participated in the treatment of throat swab viral load concentration in the early stage of the epidemic outbreak. The results showed that individual differences were significant in different patients, and viral load differences were significant on different dates after admission. Pan et al.(Pan et al., 2020) found that viral load reached peak value 5-6 days after the onset of symptoms in the throat swabs of confirmed patients in Beijing. Wang et al.(Wang et al., 2020) tested saliva samples from 23 patients of different ages in two hospitals in Hong Kong and found that the viral load peaked in the first week after symptom onset and then decreased over time. Figure 2 presents a representative comparison of viral load changes in mouth, nose and throat swabs from 5 medical reports involving 51 patients. It can be seen that the viral concentration of the COVID-19 patients (asymptomatic) varies greatly among different patients, and the same patient varies greatly at different time periods after infection, generally reaching the peak at 4-6 days after onset, with the maximum of 10^9 copies/ml. This suggests that if there are asymptomatic patients in a centrally air-conditioned indoor space, the virus concentration and transmission risk of the sprayed droplets or saliva droplets greatly differ.

Affected by the degree of infection, time and other factors, although the virus concentration exhaled from different parts of the respiratory tract of an infected person is different, for a certain respiratory activity, the virus concentration in the exhaled droplets of various particle sizes can be considered to be the same. Therefore, when discussing the transmission risk of exhaled droplets, the number of viruses contained in droplets of different particle sizes is positively correlated with the total volume of droplets in the range of particle sizes, which can represent the initial level of virus concentration and transmission risk of such droplets.

Figure 3 shows the analysis of total volume and volume ratio of the exhaled droplets in different particle size ranges based on five medical reports, such as breathing, sneezing and coughing (Chen et al., 2020; Duguid et al., 1946, 1954; Lindsley et al., 2012; Morawska et al., 2009). It can be seen that although the size distribution of droplets reported in different studies is different due to differences in instruments and methods(DuguidJP; "Guidelines for preventing the transmission of Mycobacterium tuberculosis in health-care facilities, 1994," 1994; LoudonRG & RobertsRM, 1967), the overall rules are similar. Infected persons exhale a large number of small-size particles, but a small number of large-size droplets, with a large particle size range (1~2 000 μ m). Although the number of small particle size droplets is much higher than

that of large particle size droplets (60~100 μm), because of their small single size, the cumulative volume of small particle size droplets is much smaller than that of large particle size droplets. Therefore, the risk of virus transmission of large droplets is much higher, with a difference of up to 3 to 4 orders of magnitude. It reminds us that the number of small droplets floating with the air in the air conditioning system may be much larger than that of larger droplets, but the total volume of the small droplets is much smaller than the total volume of the large droplets, so the small droplets are not the main contradiction of propagation.

(2) Survival rate of spittle with different particle sizes

The droplets with a smaller particle size emitted by indoor infected persons float in the air, while those with a larger particle size settle on the surface. What are the effects of air conditioning on the survival and transmission risk of virus droplets with different particle sizes? Only through medical experiments, can this question be answered. In medicine, the virus culture solution which is similar to human saliva is usually atomized by a nozzle and then released into a small chamber, or titrated to the surface of an object. After a certain period of time, samples are taken to detect changes in concentration to find the decay behavior.

Figure 4 shows the change of relative survival rate of respiratory viruses in the air with atomized droplet size according to 6 groups of experiments conducted by 5 scholars (Ge et al., 2014; Ijaz et al., 2018; Pyankov et al., 2012; Sattar et al., 1984). In order to eliminate the coupling effects of other factors, the selected experimental conditions are all air-conditioned environmental experimental conditions with a temperature of 18~25 $^{\circ}\text{C}$ and a relative humidity of 40~60%, and are basically similar. The value C in C/C_0 is the concentration value that aerosolized for 1 hour after the virus atomization. It can be seen that the survival rate of the atomized droplet viruses in the air is positively correlated with the particle size, that is, the larger the atomized droplet size, the higher the survival rate and the greater the risk of transmission. The larger the particle size of the atomized droplets, the more viruses they can carry. Moreover, the longer the water takes to evaporate due to the heat and mass transfer between the droplets and the environment, the slower the survival environment of the virus deterioration, leading to a significant increase in the risk of transmission. The results suggest that although a small particle size droplet nucleus can float in the air for a longer period of time, and the transmission risk is far inferior to the initial stage just after leaving the host.

Figure 5 shows the relative survival rate of respiratory viruses obtained from 12 groups of experiments in 6 reports with the change of titration volume on different surfaces (Chin et al., 2020; Doremalen et al., 2020; Doremalen et al., 2013; Greatorex et al., 2011; Sakaguchi et al., 2010; Warnes et al., 2015). In order to eliminate the coupling effects of other factors, the selected experimental conditions were all air-conditioned conditions with a temperature of 18~25 $^{\circ}\text{C}$ and a relative humidity of 40~60%, which are basically similar. C in C/C_0 is the concentration value that aerosolized for 1 hour after the virus atomization. It can be seen from this figure that the volume of the venomous droplet has a very obvious effect on the survival of the viruses on different surfaces: as the volume of the surface titrated liquid

decreases, the survival rate of the virus on the surface drops rapidly. Specifically, the survival rate of the virus in a 1 μ L droplet is 3 orders of magnitude lower than that in 500 μ L droplet. These medical measured data strongly prove that the larger the volume of the surface droplets, the greater the risk of transmission, and therefore they are the focus of epidemic prevention and control. The mechanism is that the size of the droplet volume directly affects the physical process of the viruses on the surface, and then has a significant impact on virus decay. According to related literature research and testing, it takes only a few minutes for 1 μ L droplets to reach equilibrium on the surface, while it may take several hours for 500 μ L droplets to reach equilibrium, which creates better conditions for the survival of the viruses.

3.2 Temperature and humidity control method based on the medical experiments

Controlling the indoor temperature and relative humidity is the most important aspect of air-conditioning systems. At present, we already know what temperature and relative humidity is most conducive to human health and comfort, and we have accumulated a wealth of knowledge in the field of building environment regulations. However, what temperature and humidity environment is the most unfavorable to the survival and transmission of respiratory viruses is a question that can only be answered through evidence-based medical experiments.

(1) Medical experiments on the effect of temperature on virus survival

In terms of the influence of environmental temperature on virus viability, Casanova et al.(Casanova et al.,2010) inoculated 10 μ L of TGEV and MHV containing $10^4\sim 10^5$ mpn into cell culture medium similar to human secretion at 4 °C, 20 °C and 40 °C, respectively, and then placed them on stainless steel surface carrier. After that, an appropriate sampling interval (1-24 hours or 7-28 days) was selected for each working condition, and then the samples were taken out for physical examination of virus survival. Prussin et al. (Prussin et al., 2018) titrated 10 μ L Phi6 virus solution with the concentration of $10^8 \sim 10^{10}$ pfu·ml⁻¹ into the polystyrene cell culture dish, and cultured at different temperatures for two hours, then the samples were taken out to analyze the survival of the viruses. They all found that higher temperature can reduce the relative survival rate of the viruses, and low temperature was more conducive to the survival of viruses, and this rule was also verified in the virus survival experiment of Chin(Chin et al., 2020). Chin et al.(Chin et al., 2020) first incubated SARS-CoV-2 in virus medium for 14 days (the final concentration was $10^{6.8}$ TCID₅₀·ml⁻¹), and then they were placed in the environment of 4 °C, 22 °C and 37 °C, respectively, and the stability of sars-cov-2 at different temperatures was measured.

Figure 6 presents the medical comparative experiment results of virus survival rate under five different temperature working conditions with 50-70%relative humidity which is a relatively comfortable air-conditioned environment. It can be seen that when the relative humidity is at a certain condition and the temperature is low, the survival rate of the surface viruses is very high. With the increase of temperature, the relative survival rate decreases significantly, and when the temperature rises to above 35 °C, most of

the viruses have lost their threat. This is mainly because the higher temperature leads to the faster evaporation rate of the surface droplets; and the more rapidly increase of various salt concentrations that is suitable for the survival of virus droplets, and acid-base imbalance, causing the decline of the viruses. The effect of temperature on the virus survival rate of virus in air is similar, that is, with the increase of temperature, the survival rate of viruses decreases significantly, but in the air, when the temperature reaches above 25 °C, the virus is basically inactivated(Colas de la Noue et al., 2014; Happer, 1961).

(2) Medical experiments on the effect of relative humidity on virus survival

In terms of the influence of relative humidity on virus viability, Lin et al.(Lin et al., 2020) carried out surface titration experiments on MS2 and Φ 6 phage viruses. They titrated 10 μ L high concentration virus suspension with concentration of $10^{10}\sim 10^{11}$ pfu \cdot ml $^{-1}$ to polystyrene cell culture plate, cultured for 1 hour under seven levels of relative humidity conditions in the range of 23%~100%, and compared the ratio of virus concentration after exposure to that before exposure in the fixed droplet. The results showed that the relative survival rate of the MS2 virus was the lowest when the relative humidity was 55%, and the relative survival rate of Φ 6 virus was the lowest when the relative humidity was 75% ~ 85%.Prussin et al. (Prussin et al., 2018) and Casanova(Casanova et al., 2010) also found similar behavior for virus survival in the range of 20% - 98% RH. Aiming at SARS-CoV-2, Smither(Smither et al., 2020) and Biryukov(Biryukov et al., 2020) respectively tested the survival of SARS-CoV-2 on tissue culture medium and different pore free surfaces under different relative humidity conditions. The study also found that the survival rate of the viruses was low at medium relative humidity, but higher at high relative humidity.

Figure 7 presents the results of medical comparative experiments on the effect of relative humidity on the relative survival rate of surface viruses obtained from five reports. In order to exclude the influence of other complex factors, the indoor temperature selected in the diagram is in the laboratory conditions with the temperature from 19 °C~25 °C which is more comfortable for the human body. It can be seen that the influence of relative humidity on the relative virus survival rate is generally U-shaped, although the virus types are different. In other words, the relative virus survival rate is high when the relative humidity is low or extremely high. When the relative humidity is in the range of 50%~70%, the relative survival rates of most viruses are low, which indicates that controlling the relative humidity at a medium level (50%~70%) is beneficial to reducing the virus survival and inhibiting the virus transmission.

People spend about 90% of their time indoors, and the respiratory disease infection is realized by the infected and susceptible individuals in the process of indoor social activities. However, due to the human ethics restriction, it is impossible to carry out human experiments on virus infection, so animal experiments are widely used in medicine. Generally, infected animals and susceptible animals are exposed in a closed space with comfortable temperature and humidity to simulate social behavior and observe the infection status. For example, same cage experiments(Mubareka et al., 2009; Sia et al., 2020) adjacent cage experiments(Kim et al., 2020; S et al., 2009), short-distance exposure downstream(S

et al., 2009), exposure to virus liquid smearing on the surface(Deng et al., 2020; Sia et al., 2020), and aerosol exposure of virus suspension(Kim et al., 2020; Sia et al., 2020), respectively correspond to common close contact, close propagation, media transmission and air transmission that are common in interpersonal social activities. Although in air-conditioned indoor spaces, the activity space for interpersonal social behavior is not as limited as in animal experiments, social distance and contact behavior are more random. Infected persons who enter the public buildings after investigation by various means are fewer than those who have participated in the experiment, and the virus concentration is generally not that high, but the evidence-based medical experiments can help readers understand the risk of virus transmission in the operation of the air-conditioning system from another level. Some scholars have also carried out medical experiments on the influence of the temperature and humidity environment on the transmission of infection between animals, exposing a number of experimental animals that have been diagnosed with the viruses and a number of healthy animals in a limited box space with the same temperature and adjustable relative humidity. The changes in the viral load, infection rate or mortality of the animals on each day after exposure were observed. It was found that the infection rate or mortality rate with the change of indoor air temperature and relative humidity has an influence similar to that of the virus survival rate(Herlocher et al., 2004; Marr et al., 2019).

(3) Temperature and humidity control strategy based on medical experiment

The above medical experiments of the indoor temperature and humidity environment on virus survival and animal infection transmission suggest that during the outbreak of respiratory viruses, especially in the winter, raising the indoor air temperature through the air-conditioning or heating systems can achieve thermal comfort for the human body, which is more conducive to inhibit virus activity and reduce the risk of infection between people. The suggestion to stop air conditioning or heating in winter will cause the indoor temperature too low, which is not good for the health of indoor personnel, and may increase the risk of virus transmission. It is recommended that when the air-conditioning or heating systems are running, opening windows for ventilation or increasing the amount of fresh air may cause the indoor temperature too low or even resulting in the existing system having difficulty in bearing the heavy load. At this time, the indoor temperature is close to the outdoor, causing a great waste of energy and may increase the risk of virus transmission. Since most air-conditioning or heating systems, especially split air-conditioners, do not humidify, the relative humidity in the room drops rapidly after heating, which may increase the risk of virus transmission. Therefore, an appropriate increasing in relative humidity is a very important means. In summer, the operation of the air-conditioning systems reduces the room temperature, although it may increase the virus activity and transmission risk to a certain extent, but due to its dehumidification effect, the indoor relative humidity can be brought to a moderate state, thereby generally inhibiting the virus activity. In particular, the pathogens released indoors by infected persons are in the form of droplets, so dehumidification can collect the potential pathogens in the air from the source, avoiding them from floating in the air, greatly reducing the harm to people indoors and reducing the spread risk.

Although based on the evidence-based medical experiments and combined with the basic principles of indoor environment regulation, the temperature and humidity regulation strategies of the air-conditioning or heating systems during the outbreak of the epidemic has been established, due to the coupling complexity of the problem, there are still many issues worthy of more in-depth study.

3.3 One-time removal effect of the filter layers on particles containing pathogens

Whether in distributed or centralized environmental control equipment and systems, there are filters of various levels including primary efficiency, medium efficiency, and high efficiency. In some areas with more serious pollution, the owners of residential and public buildings will also install air purifiers to meet the requirements of higher indoor air quality. From the previous analysis, it is not difficult to find that the size of the droplets exhaled by indoor infected persons has a wide distribution range, and the droplet nuclei are formed after the water evaporates rapidly and floats in the air with the airflow generated by the air conditioner, which leads to the risk of transmission. Since the risk of virus transmission of droplet nuclei of different particle sizes is different, searching for the influence of filters (filter layers) on the removal of particles with different particle sizes based on related experiments is an important scientific basis for risk assessment of the spread of air-conditioning system filters or air purifiers during the epidemic.

Some scholars(Emmerich et al., 2013; Miller-Leiden et al., 1996; Williamw et al., 1998) have found that particle filters commonly used in Heating, Ventilation and Air Conditioning (HVAC) systems can also be used to reduce the risk of airborne infectious diseases. For particles less than about 50 μm in diameter, the evaporation usually takes place within a few seconds(Chen & Zhao, 2010). After rapid evaporation, the droplet core containing mixed solid particles (including any infectious particles) still exists, and its particle size is related to the initial droplet diameter, which is generally 26~35% of the initial diameter(Nardell et al., 2001). Relevant experimental studies have been carried out(Blachere et al., 2009; Lindsley et al., 2010; Lindsley et al., 2010; Noti et al., 2012; Yang et al., 2011), testing the one-time removal efficiency of different grades of filters for infectious droplet nucleuses with particle sizes ranging from 0.3 to 10 μm . The results show that HVAC filters can effectively remove infectious droplet nuclei in the environment, and some high efficiency filters can even reach more than 90%. Figure 8 summarizes the data of one-time filtration efficiency of HVAC filters of different grades on infectious droplet nuclei in the above studies. It can be seen from the figure that: 1) The average filtration efficiency of infectious droplet nuclei ranges from 10.5% of MERV 4 filter to 99.9% of HEPA filter, and the filtration efficiency is significantly different.2) The higher the filter level is, the better is the filtering effect. However, when the filter level reaches a certain level (MERV 13 and above), the filtering efficiency will be basically stable at above 90%. Therefore, regardless of the level of the air conditioner used indoors, it can achieve the effect of removing infectious droplets and reduce the risk of infection.

The filter efficiency of different filter layers varies with the particle size, as shown in Figure 9(Davies et al., 2013; Lee et al., 2008; Macintosh et al., 2008; Oberg et al., 2008). From this figure, it can be further seen that different filter layers have different filtering effects on particles of different sizes in actual use. It can be found that for the same filter layer, the smaller the particle size, the lower the filtration efficiency. As the particle size increases, the filtration efficiency increases rapidly until a certain particle size where it becomes stable. Therefore, this figure can fully illustrate that the range of indoor pollutant particles removed by filters and air purifiers in air conditioning systems is mainly for larger particle sizes, and their filtering and purification effects are very significant, with an average efficiency of more than 80%.

4. Transmission Risk Of Central Air Conditioning System Operation

The centralized air-conditioning systems with return air is representative. The principle of indoor temperature and humidity environment and air quality control is shown in Figure 10. The heat and humidity loads generated by the envelope structure of each room and indoor personnel equipment enter the air conditioning unit through the return air. After passing through the primary (or middle) efficiency filter layer, the heat exchange is conducted with hot or cold water, and then the humidification or dehumidification treatment is carried out. Finally, it is pressurized by the fan and sent to each room through the pipeline. In order to meet indoor hygiene requirements, a certain amount of outdoor fresh air must be introduced to dilute and reduce the concentration of indoor pollutants. The fresh air ratio is related to building functions, outdoor pollution, indoor load, etc. Civil buildings, the fresh air ratio can be as low as 5-10%, or configured according to the minimum indoor air volume per person, and for hospital infectious wards can be as high as 100%. Installing primary (medium) efficiency filters in air-conditioning units (general civil buildings), as well as additional air purifiers for rooms in severely polluted areas, and even some special hospital buildings also install high-efficiency air purifiers to further improves indoor air quality. For a general air-conditioning system, when the temperature of the cold and heat source is constant, the supply air temperature and relative humidity are basically determined, and the dynamic demand of the room air conditioning load is mainly adjusted by the supply air volume. When the amount of fresh air that meets the sanitary requirements of the room is constant, it is an inevitable choice to increase the number of return air cycles to enhance the heat and moisture load adjustment capacity of the air conditioning system. The corresponding number of cycle air changes (ACH) may be as high as ten times. The processed return air flow is sent to each room again, questioned by increasing the risk of virus transmission during the outbreak. Therefore, according to the aforementioned experimental evidence of the particle size distribution characteristics of the droplet nuclear particles exhaled by the indoor infected person and the filtration efficiency of the filter layer on different particles, and combined with the operating characteristics of the centralized air-conditioning system of ordinary public buildings, the propagation risks of different operating conditions corresponding to the typical filter purifier configuration are analyzed.

The air-conditioning unit of the centralized air-conditioning systems is generally equipped with primary and medium-efficiency filters, and there are also some better-configured medium-efficiency filters. It is assumed that the comprehensive filtration efficiency of the full particle size range of the filter is 30%, 50%, and 70%. Due to the aggravation of environmental haze and PM2.5 pollution, more and more air purifiers are used independently in public buildings and the call for designing air purification equipment in the system is gradually increasing. It is assumed that the comprehensive filtration efficiency of the full particle size range of the air purifier is 40%, 75% and 95%(Cui et al., 2017), as shown in Table 1. In order to focus on the risk of transmission of droplets (droplet nuclei) particles released into the room by the infected person during the epidemic period through the air-conditioning system, we use the viral load of the infected person's cough and the total volume of each exhaled droplet(Chen et al., 2020) to obtain the concentration C_0 of potential pathogenic particles discharged by the indoor infected person. It is supposed that the droplets are uniformly distributed in the indoor air and exist in the return air flow. After mixing with fresh air, they pass the filter or/and air purifier of the air-conditioning unit, and finally are sent to each room for continuous circulation. During the process, the natural settlement and reproduction of the droplets in the indoor and air-conditioning system pipe network are not considered. Fresh air has a certain dilution effect on potential indoor pathogenic particulates, but the number of fresh air changes (usually 0.5~2 times) is much smaller than that of return air. Therefore, the impact of this is ignored when analyzing the risk of air conditioning system transmission.

Table 1 The efficiency of different filter/purification equipment in air conditioning system

	Filtration efficiency α_1	Purification efficiency α_2
Minimum Configuration	30%	40%
Medium Configuration	50%	75%
Top Configuration	70%	95%

Since the transmission risk of centralized air-conditioning mainly comes from the circulation of air, figure 11 shows the different grade filter and air purifier configurations of the air conditioning system, and the corresponding indoor air circulation system's removal effect on potential pathogens after one air change. In the figure, the relative concentration ratio C/C_0 represents the relative size of indoor concentration of particulate matter of potential pathogen after one cycle. As it can be seen 1) regardless of the level of air conditioning system configuration, it can effectively reduce the concentration of indoor pathogen particles, that is, effectively reduce the risk of indoor virus transmission. 2) For an ordinary centralized air-conditioning system with only a filter, after the indoor air is circulated once, the relative concentration of pathogenic particles will decrease as the efficiency of the filter increases, thereby reducing the risk of transmission. 3) If an air purifier is installed on the basis of an ordinary air-conditioning system, the effect of reducing the relative concentration of indoor pathogenic particles will be more obvious, and one cycle can reduce the risk of transmission by up to 98.5%.

In fact, in order to take away the waste heat and humidity in the room, the number of air changes of the circulating air of the central air conditioning system increases with the increase in load. Figure 12 is a diagram showing the relative concentration of pathogen particles corresponding to the change of the system running time under different air changes of circulating air when the air conditioning system is only equipped with a primary and medium-efficiency filter (that is, the medium configuration $\alpha_1=50\%$, $\alpha_2=0$ in Table 1). It can be seen that 1) When the different air changes with the circulating air is 3 times/h, the relative concentration of pathogen particles can be reduced by about 90% after one hour. When the number of air changes of the circulating air reaches 7 times/h or more, the relative concentration of pathogen particles is only 0.1% in one hour. The risk of infection is very low. 2) Although the airflow organization of the centralized air conditioner may send the air from the room with the infected person to other rooms, after the circulating air is processed by the filtering device, most of the potential pathogen particles are captured and removed, which greatly reduces the risk of transmission. It is not difficult to predict that if an air purifier is independently purchased and put into operation in a centralized air-conditioning system, it can achieve a better effect on removing potential indoor pathogen particle pollutants.

The above analysis shows that the centralized air-conditioning system operating normally during the epidemic has obvious effects of removing pathogenic particles and reducing the risk of transmission. First of all, the temperature and relative humidity are adjusted to the thermal comfort zone of the human body. Medical experiments have shown that it can accelerate the decline and death of a viruses to a greater extent, and is not conducive to the spread of the viruses between animals or persons. Secondly, the filter or air purifier in the air conditioning system has a better filtering and removal effect on the larger particle sizes of the pathogen particle carrier, and the medical experiments show that the larger the droplet nuclear virus load, the higher the virus load and the longer the survival time. This is the main contradiction of the respiratory virus transmission, so the risk of transmission after captured and removed can be greatly reduced. The droplet nuclei remaining in the circulating air of the air-conditioning system are mainly of small size. Although the number is large, the cumulative volume is small, and the decay is faster, the risk of transmission is lower. Of course, it does not mean that the droplet nuclei sent into each room in the circulating air are completely free from the risk of transmission. Small particles captured on the filter layer may be swept up by the airflow again, causing secondary diffusion. It is necessary to further understand the living environment and reproduction rules of the viruses from the medical perspective, especially the decay characteristics of the viruses in the external environment from the moment it leaves the host, and to find a more scientific answer by combining with the movement rules of droplet nuclei particles caused by air circulation in the centralized air conditioning system.

5. Conclusions And Tips

In this paper, based on the existing medical experimental studies, the risk of the indoor SARS-COV-2 transmission is analyzed from three basic links of virus transmission. On the basis of the above, the risk is combined with the operation of the air-conditioning systems. Taking the primary return air-conditioning

system as an example, the effect of air-conditioning operation on the spread of SARS-CoV-2 in the indoor environment is comprehensively analyzed. The research results show that:

1) Among three basic links of virus transmission, large particle size droplets exhaled by an infected person at the source of infection have the greatest risk in the process of indoor virus transmission, and the risk in the transport path comes next. For susceptible people, the risk is greater only if they have close contact with infected persons without adequate respiratory protection measures.

2) When the temperature is 20~25°C and the relative humidity is 50%~70%, the viability of the viruses in the air and on the surface is weak, and the inactivation is faster. Therefore, in an air-conditioned room, the air-conditioning system can adjust the temperature and humidity to ensure human comfort and to create an indoor environment that is not conducive to the survival of SARS-CoV-2, thereby effectively inhibiting the spread of the viruses to a certain extent and reducing the risk of indoor virus transmission.

3) Because the virus content is proportional to the cube of the particle size, and the efficiency of the filter or air purifier in the centralized air conditioner increases rapidly with the increase of the diameter of the pathogen-containing particles, increase in the number of air changes of the circulating air accelerates the removal of potential pathogen particles. Therefore, the operation of the air-conditioning system is helpful to solve the main contradiction. The return air circulation may also accelerate the mixing of the air in each room, but the small particle size, long floating time, and rapid decay of these droplet nuclei are secondary to the spread of the epidemic.

4) The operation of the air-conditioning system can effectively reduce the concentration of potential pathogens in an air-conditioned room. The quantitative analysis shows that even under relatively poor cycle condition of 1 time/h, the residual rate of potential pathogens is only 40% after air conditioning operation for 1 hour, and the risk of infection is effectively reduced, while under the condition of good ventilation of 7 times/h and above, within 1 hour of air conditioning operation, the virus survival rate is only about 0.1% of the initial situation, and the infection risk is only one thousandth of the initial situation.

5) During the epidemic, people do not need to worry too much about whether SARS-CoV-2 will be transmitted through the air-conditioning system. Scientific, reasonable and safe use of air-conditioner can not only create a comfortable living environment, but also effectively reduce the risk of indoor infection.

Declarations

- **Ethics approval and consent to participate**

Not applicable.

- **Consent for publication**

Not applicable.

- **Availability of data and materials**

All data used during the study are available from the corresponding author by request.

- **Competing interests**

The authors declare there are no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

- **Funding**

This work was supported by the National Natural Science Foundation of China (52078314), and the Sichuan Science and Technology Program (2019YFS0051 & 2020YFS0439).

- **Authors' contributions**

Yonghong Jia: Data curation, Writing-Original draft preparation.

Yue Xiang: Reviewing and Editing.

Shurui Guo: Reviewing and Editing.

Lei Guo: Reviewing and Editing.

Zhu Cheng: Reviewing and Editing.

Luyao Guo: Reviewing.

Yin Zhang: Supervision.

Li Zhang: Supervision.

Enshen Long: Conceptualization, Methodology.

- **Authors' information**

Yonghong Jia: Jiayonghong0301@163.com. BS

Yue Xiang: xiangyue@cqust.edu.cn. MS

Shurui Guo: Sherrygsr@outlook.com. MS

Lei Guo: 370027526@qq.com. MS

Luyao Guo: Gloriagly@outlook.com. BS

Zhu Cheng: scchengzhu@126.com. PHDT

Yin Zhang: cdzhangyin@163.com. PHD

Li Zhang: 404192997@qq.com.PHDT

Corresponding author: Enshen Long: longes2@163.com. PHD

References

1. Becker, R., Haquin, G., & Kovler, K. (2013). Air change rates and radon accumulation in rooms with various levels of window and door closure. *Journal of Building Physics*, 38(3), 234-261. doi:10.1177/1744259113506071
2. Biryukov, J., Boydston, J. A., Dunning, R. A., Yeager, J. J., Wood, S., Reese, A. L., . . . Altamura, L. A. (2020). Increasing Temperature and Relative Humidity Accelerates Inactivation of SARS-CoV-2 on Surfaces. *mSphere*, 5(4). doi:10.1128/mSphere.00441-20
3. Blachere, F. M., Lindsley, W. G., Pearce, T. A., Anderson, S. E., Fisher, M., Khakoo, R., . . . Beezhold, D. H. (2009). Measurement of airborne influenza virus in a hospital emergency department. *Clin Infect Dis*, 48(4), 438-440. doi:10.1086/596478
4. Buonanno, G., Stabile, L., & Morawska, L. (2020). Estimation of airborne viral emission: Quanta emission rate of SARS-CoV-2 for infection risk assessment. *Environ Int*, 141, 105794. doi:10.1016/j.envint.2020.105794
5. Cao, B., Wang, Y., Wen, D., Liu, W., Wang, J., Fan, G., . . . Wang, C. (2020). A Trial of Lopinavir-Ritonavir in Adults Hospitalized with Severe Covid-19. *New England Journal of Medicine*, 382(19), 1787-1799. doi:10.1056/NEJMoa2001282
6. Casanova, L. M., Jeon, S., Rutala, W. A., Weber, D. J., & Sobsey, M. D. (2010). Effects of air temperature and relative humidity on coronavirus survival on surfaces. *Appl Environ Microbiol*, 76(9), 2712-2717. doi:10.1128/AEM.02291-09
7. Chen, C., & Zhao, B. (2010). Some questions on dispersion of human exhaled droplets in ventilation room: answers from numerical investigation. *Indoor Air*, 20(2), 95-111. doi:10.1111/j.1600-0668.2009.00626.x
8. Chen, S. C., & Liao, C. M. (2010). Probabilistic indoor transmission modeling for influenza (sub)type viruses. *J Infect*, 60(1), 26-35. doi:10.1016/j.jinf.2009.09.015
9. Chen, W., Zhang, N., Wei, J., Yen, H.-L., & Li, Y. (2020). Short-range airborne route dominates exposure of respiratory infection during close contact. *Building and Environment*, 176. doi:10.1016/j.buildenv.2020.106859
10. Cheng, Y.-H., & Liao, C.-M. (2013). Modeling control measure effects to reduce indoor transmission of pandemic H1N1 2009 virus. *Building and Environment*, 63, 11-19. doi:10.1016/j.buildenv.2013.01.014
11. Chin, A. W. H., Chu, J. T. S., Perera, M. R. A., Hui, K. P. Y., Yen, H.-L., & Chan, M. C. W. (2020). Stability of Middle East respiratory syndrome__coronavirus (MERS-CoV) under different__environmental

- conditions. *The Lancet*, 1(1), E10.
12. Chin, A. W. H., Chu, J. T. S., Perera, M. R. A., Hui, K. P. Y., Yen, H.-L., Chan, M. C. W., . . . Poon, L. L. M. (2020). Stability of SARS-CoV-2 in different environmental conditions. *The Lancet Microbe*, 1(1). doi:10.1016/s2666-5247(20)30003-3
 13. Colas de la Noue, A., Estienney, M., Aho, S., Perrier-Cornet, J. M., de Rougemont, A., Pothier, P., . . . Belliot, G. (2014). Absolute Humidity Influences the Seasonal Persistence and Infectivity of Human Norovirus. *Appl Environ Microbiol*, 80(23), 7196-7205. doi:10.1128/AEM.01871-14
 14. Correia, G., Rodrigues, L., Gameiro da Silva, M., & Goncalves, T. (2020). Airborne route and bad use of ventilation systems as non-negligible factors in SARS-CoV-2 transmission. *Med Hypotheses*, 141, 109781. doi:10.1016/j.mehy.2020.109781
 15. Davies, A., Thompson, K. A., Giri, K., Kafatos, G., Walker, J., & Bennett, A. (2013). Testing the efficacy of homemade masks: would they protect in an influenza pandemic? *Disaster Med Public Health Prep*, 7(4), 413-418. doi:10.1017/dmp.2013.43
 16. Deng, W., Bao, L., Gao, H., Xiang, Z., Qu, Y., Song, Z., . . . Qin, C. (2020). Rhesus macaques can be effectively infected with SARS-CoV-2 via ocular conjunctival route. *bioRxiv* doi:10.1101/2020.03.13.990036
 17. Doremalen, N. v., Morris, D. H., Holbrook, M. G., Gamble, A., & Williamson, B. N. (2020). Aerosol and Surface Stability of SARS-CoV-2__as Compared with SARS-CoV-1. *The new england journal of medicine*, 1564-1567.
 18. Doremalen, V., Bushmaker, T., & Munster, V. J. (2013). Stability of Middle East respiratory syndrome coronavirus (MERS-CoV) under different environmental conditions. *Eurosurveillance*, 18(38).
 19. Duguid, J. P., M.B., & B.Sc. (1954). The numbers and the sites of origin of the droplets expelled during expiratory activities. *Edinburgh Medical Journal*.
 20. The size and the duration of air-carriage of respiratory droplets and droplet-nuclei[J]. *J Hyg (Lond)*, 1946,44(6):471-479. DOI: 10.1017/s0022172400019288.
 21. Emmerich, S. J., Heinzerling, D., Choi, J.-i., & Persily, A. K. (2013). Multizone modeling of strategies to reduce the spread of airborne infectious agents in healthcare facilities. *Building and Environment*, 60, 105-115. doi:10.1016/j.buildenv.2012.11.013
 22. Farnham, A., Alleyne, L., Cimini, D., & Balter, S. (2014). Legionnaires' disease incidence and risk factors, New York, New York, USA, 2002-2011. *Emerg Infect Dis*, 20(11), 1795-1802. doi:10.3201/eid2011.131872
 23. Ge, S., Kuehn, T. H., Abin, M., Verma, H., Bekele, A., Mor, S. K., . . . Zuo, Z. (2014). Airborne Virus Survivability During Long-Term Sampling Using a Non-Viable Andersen Cascade Impactor in an Environmental Chamber. *Aerosol Science and Technology*, 48(12), 1360-1368. doi:10.1080/02786826.2014.984800
 24. Greatorex, J. S., Digard, P., Curran, M. D., Moynihan, R., Wensley, H., Wreghitt, T., . . . Nguyen-Van-Tam, J. S. (2011). Survival of influenza A(H1N1) on materials found in households: implications for infection control. *PloS one*, 6(11), e27932. doi:10.1371/journal.pone.0027932

25. Guarnieri, M., & Balmes, J. R. (2014). Outdoor air pollution and asthma. *The Lancet*, 383(9928), 1581-1592. doi:10.1016/s0140-6736(14)60617-6
26. Guidelines for preventing the transmission of *Mycobacterium tuberculosis* in health-care facilities, 1994. (1994).
27. HARPER, G. J. (1961). Airborne micro-organisms_ survival tests with four viruses. *Epidemiology & Infection*, 59(4), 479-486.
28. Herlocher, M. L., Truscon, R., Elias, S., Yen, H.-L., Roberts, N. A., Ohmit, S. E., & Monto, A. S. (2004). Influenza Viruses Resistant to the Antiviral Drug Oseltamivir_ Transmission Studies in Ferrets. *The Journal of Infectious Diseases*, 190(9), 1627–1630.
29. Hoseinzadeh, E., Safoura, J., Farzadkia, M., Mohammadi, F., Hossini, H., & Taghavi, M. (2020). An updated min-review on environmental route of the SARS-CoV-2 transmission. *Ecotoxicol Environ Saf*, 202, 111015. doi:10.1016/j.ecoenv.2020.111015
30. <https://health.clevelandclinic.org/does-air-conditioning-spread-the-coronavirus/>.
31. <https://rlt-geraete.de/>.
32. <https://www.ashrae.org/technical-resources/resources>.
33. <https://www.buildup.eu/en/practices/publications/covid-19-guidance-rehva>.
34. <https://www.cibse.org/coronavirus-covid-19/coronavirus-covid-19-and-hvac-systems>.
35. Ijaz, M. K., Brunner, A. H., & Sattar, S. A. (1985). Survival Characteristics of Airborne Human Coronavirus 229E. *Journal of General Virology*, 66, 2743-2274.
36. Jayaweera, M., Perera, H., Gunawardana, B., & Manatunge, J. (2020). Transmission of COVID-19 virus by droplets and aerosols: A critical review on the unresolved dichotomy. *Environ Res*, 188, 109819. doi:10.1016/j.envres.2020.109819
37. Jingjing Cui, Xuebin Yang, Henggen Shen, & Li, Q. (2017). Experimental study on indoor air cleaner based on different types of air filter units. *HV&AC*.
38. Kim, Y. I., Kim, S. G., Kim, S. M., Kim, E. H., Park, S. J., Yu, K. M., . . . Choi, Y. K. (2020). Infection and Rapid Transmission of SARS-CoV-2 in Ferrets. *Cell Host Microbe*, 27(5), 704-709 e702. doi:10.1016/j.chom.2020.03.023
39. Klepeis, N. E., Nelson, W. C., OTT, W. R., Robinson, J. P., S, A. M. T., Witzer, . . . Engelmann, W. H. (2020). The National Human Activity Pattern Survey (NHAPS): a resource for assessing exposure to environmental pollutants.
40. Lee, S. A., Grinshpun, S. A., & Reponen, T. (2008). Respiratory performance offered by N95 respirators and surgical masks: human subject evaluation with NaCl aerosol representing bacterial and viral particle size range. *Ann Occup Hyg*, 52(3), 177-185. doi:10.1093/annhyg/men005
41. Lin, K., & Marr, L. C. (2020). Humidity-Dependent Decay of Viruses, but Not Bacteria, in Aerosols and Droplets Follows Disinfection Kinetics. *Environ Sci Technol*, 54(2), 1024-1032. doi:10.1021/acs.est.9b04959

42. Lindsley, W. G., Blachere, F. M., Davis, K. A., Pearce, T. A., Fisher, M. A., Khakoo, R., . . . Beezhold, D. H. (2010). Distribution of airborne influenza virus and respiratory syncytial virus in an urgent care medical clinic. *Clin Infect Dis*, 50(5), 693-698. doi:10.1086/650457
43. Lindsley, W. G., Blachere, F. M., Thewlis, R. E., Vishnu, A., Davis, K. A., Cao, G., . . . Beezhold, D. H. (2010). Measurements of airborne influenza virus in aerosol particles from human coughs. *PloS one*, 5(11), e15100. doi:10.1371/journal.pone.0015100
44. Lindsley, W. G., Pearce, T. A., Hudnall, J. B., Davis, K. A., Davis, S. M., Fisher, M. A., . . . Beezhold, D. H. (2012). Quantity and size distribution of cough-generated aerosol particles produced by influenza patients during and after illness. *J Occup Environ Hyg*, 9(7), 443-449. doi:10.1080/15459624.2012.684582
45. LoudonRG, & RobertsRM. (1967). Droplet expulsion from the respiratory tract[J]. *Am Rev Respir Dis*, 1967,95(3):435-442.
46. Lu, J., Gu, J., Li, K., Xu, C., Su, W., Lai, Z., . . . Yang, Z. (2020). COVID-19 Outbreak Associated with Air Conditioning in Restaurant, Guangzhou, China, 2020. *Emerg Infect Dis*, 26(7), 1628-1631. doi:10.3201/eid2607.200764
47. Macintosh, D. L., Myatt, T. A., Ludwig, J. F., Baker, B. J., Suh, H. H., & Spengler, J. D. (2008). Whole house particle removal and clean air delivery rates for in-duct and portable ventilation systems. *J Air Waste Manag Assoc*, 58(11), 1474-1482. doi:10.3155/1047-3289.58.11.1474
48. Mao, N., An, C. K., Guo, L. Y., Wang, M., Guo, L., Guo, S. R., & Long, E. S. (2020). Transmission risk of infectious droplets in physical spreading process at different times: A review. *Building and Environment*, 185. doi:10.1016/j.buildenv.2020.107307
49. Marr, L. C., Tang, J. W., Van Mullekom, J., & Lakdawala, S. S. (2019). Mechanistic insights into the effect of humidity on airborne influenza virus survival, transmission and incidence. *J R Soc Interface*, 16(150), 20180298. doi:10.1098/rsif.2018.0298
50. Miller-Leiden, S., Lobascio, C., Nazaroff, W. W., & Macher, J. M. (1996). Effectiveness of in-room air filtration and dilution ventilation for tuberculosis infection control. *J Air Waste Manag Assoc*, 46(9), 869-882. doi:10.1080/10473289.1996.10467523
51. Morawska, L. (2006). Droplet fate in indoor environments, or can we prevent the spread of infection? *Indoor Air*. doi:10.1111/j.1600-0668.2006.00432.x
52. Morawska, L., Johnson, G. R., Ristovski, Z. D., Hargreaves, M., Mengersen, K., S. Corbett, . . . Katoshevski, D. (2009). Size distribution and sites of origin of droplets expelled during expiratory activities *Journal of Aerosol Science*.
53. Morawska, L., & Milton, D. K. (2020). It is Time to Address Airborne Transmission of COVID-19. *Clin Infect Dis*. doi:10.1093/cid/ciaa939
54. Mubareka, S., Lowen, A. C., Steel, J., Coates, A. L., Garcia-Sastre, A., & Palese, P. (2009). Transmission of influenza virus via aerosols and fomites in the guinea pig model. *J Infect Dis*, 199(6), 858-865. doi:10.1086/597073

55. Nardell, E. A. (2001). Chapter 11: disinfecting air. *Indoor air quality handbook*, McGraw-Hill, New York, NY.
56. Noti, J. D., Lindsley, W. G., Blachere, F. M., Cao, G., Kashon, M. L., Thewlis, R. E., . . . Beezhold, D. H. (2012). Detection of infectious influenza virus in cough aerosols generated in a simulated patient examination room. *Clin Infect Dis*, 54(11), 1569-1577. doi:10.1093/cid/cis237
57. Oberg, T., & Brosseau, L. M. (2008). Surgical mask filter and fit performance. *Am J Infect Control*, 36(4), 276-282. doi:10.1016/j.ajic.2007.07.008
58. Olsen, S. J., Chang, H. L., Cheung, T. Y., Tang, A. F., Fisk, T. L., Ooi, S. P., . . . Dowell, S. F. (2003). Transmission of the severe acute respiratory syndrome on aircraft. *N Engl J Med*, 349(25), 2416-2422. doi:10.1056/NEJMoa031349
59. Pan, L., Yujing Zhang, Xu Yan, & Zhang, L. (2020). Operation and Management Guidelines for Air Conditioning and Ventilation Systems in Office and Public Places during COVID- 19 Outbreak. *Journal of Environmental Hygiene*.
60. Pan, Y., Zhang, D., Yang, P., Poon, L. L. M., & Wang, Q. (2020). Viral load of SARS-CoV-2 in clinical samples. *The Lancet Infectious Diseases*, 20(4), 411-412. doi:10.1016/s1473-3099(20)30113-4
61. Prussin, A. J., Schwake, D. O., Lin, K., Gallagher, D. L., & Buttling, L. (2018). Survival of the Enveloped Virus Phi6 in Droplets as a Function of Relative Humidity. *Applied and Environmental Microbiology*, 84(12).
62. Pyankov, O. V., Bodnev, S. A., Pyankova, O. G., & Agranovski, I. E. (2018). Survival of aerosolized coronavirus in the ambient air. *J Aerosol Sci*, 115, 158-163. doi:10.1016/j.jaerosci.2017.09.009
63. Pyankov, O. V., Pyankova, O. G., & Agranovski, I. E. (2012). Inactivation of airborne influenza virus in the ambient air. *Journal of Aerosol Science*, 53, 21-28. doi:10.1016/j.jaerosci.2012.05.011
64. Qu, G., Li, X., Hu, L., & Jiang, G. (2020). An imperative need for research on the role of environmental factors in transmission of novel coronavirus (COVID-19). *Environmental Science* \square doi:10.1021/acs.est.0c01102
65. REHVA_COVID-19_guidance_document_ver2_20200403_.
66. S, M., C, L. A., & J, S. (2009). Transmission of influenza virus via aerosols and fomites in the guinea pig model[J]. *The Journal of infectious diseases*, 2009, 199(6): 858-865.
67. Sakaguchi, H., Wada, K., Kajioaka, J., Watanabe, M., Nakano, R., Hirose, T., . . . Aizawa, Y. (2010). Maintenance of influenza virus infectivity on the surfaces of personal protective equipment and clothing used in healthcare settings. *Environ Health Prev Med*, 15(6), 344-349. doi:10.1007/s12199-010-0149-y
68. Sattar, S. A., Ijaz, M. K., Johnson-Lussenburg, C. M., & Springthorpe, V. S. (1984). Effect of relative humidity on the airborne survival of rotavirus SA11. *Appl Environ Microbiol*, 47(4), 879-881. doi:10.1128/AEM.47.4.879-881.1984
69. Shengzhi Zhao, Ailing Zhang, & Zhang, X. (2010). Three basic steps in the epidemic of infectious diseases. *Veterinary Clinical*.

70. Sia, S. F., Yan, L. M., Chin, A. W. H., Fung, K., Choy, K. T., Wong, A. Y. L., . . . Yen, H. L. (2020). Pathogenesis and transmission of SARS-CoV-2 in golden hamsters. *Nature*, 583(7818), 834-838. doi:10.1038/s41586-020-2342-5
71. Siddiqui, R., & Ahmed Khan, N. (2020). Centralized air-conditioning and transmission of novel coronavirus. *Pathog Glob Health*, 114(5), 228-229. doi:10.1080/20477724.2020.1765653
72. Simonds, A. K. (2020). 'Led by the science', evidence gaps, and the risks of aerosol transmission of SARS-COV-2. *Resuscitation*, 152, 205-207. doi:10.1016/j.resuscitation.2020.05.019
73. Smither, S. J., Eastaugh, L. S., Findlay, J. S., & Lever, M. S. (2020). Experimental aerosol survival of SARS-CoV-2 in artificial saliva and tissue culture media at medium and high humidity. *Emerg Microbes Infect*, 9(1), 1415-1417. doi:10.1080/22221751.2020.1777906
74. K.-W., Tsang, O. T.-Y., Leung, W.-S., Tam, A. R., Wu, T.-C., Lung, D. C., . . . Yuen, K.-Y. (2020). Temporal profiles of viral load in posterior oropharyngeal saliva samples and serum antibody responses during infection by SARS-CoV-2: an observational cohort study. *The Lancet Infectious Diseases*, 20(5), 565-574. doi:10.1016/s1473-3099(20)30196-1
75. Wang, B., Cao, S., Ma, J., Huang, N., Nie, J., Wang, Z., & Duan, X. (2015). 5 - time-activity factors related to air exposure. in: X. Duan, X. Zhao, B. Wang, Y. Chen, S. Cao (Eds.), *Highlights of the Chinese Exposure Factors Handbook*, Academic Press 2015, pp. 31-39.
76. Wang, J., & Du, G. (2020). COVID-19 may transmit through aerosol. *Irish Journal of Medical Science*. doi:10.1007/s11845-020-02218-2
77. Warnes, S. L., Little, Z. R., & Keevil, C. W. (2015). Human Coronavirus 229E Remains Infectious on Common Touch Surface Materials. *mBio*, 6(6), e01697-01615. doi:10.1128/mBio.01697-15
78. WHO announces COVID-19 outbreak a pandemic (<http://www.euro.who.int/en/health-topics/health-emergencies/coronavirus-covid-19/news/news/2020/3/who-announces-covid-19-outbreak-a-pandemic>).
79. WHO, WHO Coronavirus Disease (COVID-19) Dashboard, 2020. <https://covid19.who.int/>.
80. NAZAROFF, MARKNICAS, & ANDSHELLYL.MILLER. (1998). Framework for evaluating measures to control nosocomial tuberculosis transmission. *Indoor Air*.
81. Yang, W., Elankumaran, S., & Marr, L. C. (2011). Concentrations and size distributions of airborne influenza A viruses measured indoors at a health centre, a day-care centre and on aeroplanes. *J R Soc Interface*, 8(61), 1176-1184. doi:10.1098/rsif.2010.0686
82. Zhang, R., Li, Y., Zhang, A. L., Wang, Y., & Molina, M. J. (2020). Identifying airborne transmission as the dominant route for the spread of COVID-19. *Proc Natl Acad Sci U S A*, 117(26), 14857-14863. doi:10.1073/pnas.2009637117
83. Zou, L., Ruan, F., Huang, M., Liang, L., Huang, H., Hong, Z., . . . Wu, J. (2020). SARS-CoV-2 Viral Load in Upper Respiratory Specimens of Infected Patients. *N Engl J Med*, 382(12), 1177-1179. doi:10.1056/NEJMc2001737

Figures




Figure 1

Annotation T Temperature RH Relative Humidity Schematic diagram of indoor SARS-CoV-2 transmission and air conditioning operation regulation




Figure 2

Trend of viral load in the body fluids of infected persons over time




Figure 3

Volume distribution and proportion of droplet corresponding to different particle sizes




Figure 4

The relative survival rate of respiratory viruses in the air varies with particle size




Figure 5

The relative survival rate of respiratory viruses in the air changes with the titration volume




Figure 6

Ambient temperature affects the survival of viruses on surfaces




Figure 7

RH affects the survival of viruses on surfaces




Figure 8

Comparative chart of infective-particle-size-weighted filtration efficiency for various HVAC filters




Figure 9

Variation rule of primary filtration efficiency of different filter layers with particle diameter




Figure 10

Air flow chart of primary return air conditioning system




Figure 11

Comparison of potential pathogen concentration changes in different configurations of air conditioning systems after one cycle of indoor air




Figure 12

Changes in the relative concentration of pathogen particles with time under different cycles

Supplementary Files

This is a list of supplementary files associated with this preprint. Click to download.

- [Appendix1.docx](#)
- [Appendix2.docx](#)
- [Appendix3.docx](#)
- [GraphicalAbstract.png](#)